

## Company Directive

### ENGINEERING SPECIFICATION

EE SPEC: 8/10

### Relating to Emergency Rated System Transformers - 66/11.5kV and 33/11.5kV Delta/Star and Star/Star connected

#### Policy Summary

This specification covers Western Power Distribution's requirements for 7.5/15MVA, 12/24MVA and 20/40MVA delta/star and star/star continuous emergency rated system transformers. It is based on ENA Technical Specification 35-2 Issue 6 - June 2014 and must be read in conjunction with that document.

**Author:** Andrew Reynolds

**Implementation Date:** February 2020

**Approved by**



Carl Ketley-Lowe  
Engineering Policy Manager

**Date:**

14<sup>th</sup> Feb 2020

Target Staff Group	All Employees
Impact of Change	Green
Planned Assurance checks	Checks to be carried out that staff are ordering from the new framework once awarded

*All references to Western Power Distribution or WPD must be read as National Grid Electricity Distribution or NGED*

**NOTE:** The current version of this document is stored in the NGED Corporate Information Database. Any other copy in electronic or printed format may be out of date. Copyright © 2022 National Grid Electricity Distribution

## **IMPLEMENTATION PLAN**

### **Introduction**

This document defines the 66/11.5kV and 33/11.5kV CER Primary Transformers used within WPD and provides a standard with which the Purchasing Section can go out to tender with.

### **Main Changes**

The document has been updated to include outdoor LV bushings.

### **Impact of Changes**

The impact of changes affects the Procurement Team, Primary System Design, Engineering Design and Major Projects.

### **Implementation Actions**

Implementation is immediate.

### **Implementation Timetable**

This policy can be implemented with immediate effect.

## REVISION HISTORY

<b>Document Revision &amp; Review Table</b>		
<b>Date</b>	<b>Comments</b>	<b>Author</b>
February 2020	<ul style="list-style-type: none"> <li>• Inclusion of LV outdoor bushings</li> </ul>	Andrew Reynolds
January 2020	<ul style="list-style-type: none"> <li>• Inclusion of 66KV impedance envelopes</li> <li>• Standard flow rate 1.2m/s</li> <li>• Tier 2 losses date</li> </ul>	Andrew Reynolds
Feb 2017	<ul style="list-style-type: none"> <li>• Inclusion of inhibited insulating oil</li> <li>• Spelling changes and grammar</li> </ul>	Andrew Reynolds
May 2015	<ul style="list-style-type: none"> <li>• Inclusion of new standard schemes, Ashridge WTI instrument and removal of some contradictory terms</li> <li>• Inclusion of new ENATS 35-2 issue 6 2014</li> <li>• Inclusion of Eco design regulation 2009/125/EC</li> <li>• Update to latest ENATS 35-2 numbering</li> </ul>	Andrew Reynolds
04/01/2013	<ul style="list-style-type: none"> <li>• Inclusion of revision table, update of drawing references and inclusion of new Appendix 1 and 1A, inclusion of WPD Midlands transformers</li> </ul>	Andrew Reynolds

## CONTENTS

	Page
1.0 SCOPE	5
2.0 FOREWORDS	5
3.0 DEFINITIONS	5
4.0 SERVICE CONDITIONS	5
5.0 RATINGS	6
6.0 REQUIREMENTS FOR TRANSFORMERS HAVING A TAPPED WINDING	7
7.0 CONNECTION AND PHASE DISPLACEMENT SYMBOLS FOR 3 PHASE TRANSFORMERS	9
8.0 RATING PLATES	9
9.0 SAFETY, ENVIRONMENTAL AND OTHER REQUIREMENTS	9
10.0 TOLERANCES	10
11.0 TESTS	11
12.0 ELECTROMAGNETIC COMPATIBILITY (EMC)	12
14.0 TRANSFORMER DETAILS	13
15.0 CONSTRUCTION DETAILS	13
16.0 DOCUMENTATION	26
17.0 PROGRAMME AND PROGRESS INFORMATION	26
18.0 DELIVERY AND ERECTION	26
APPENDIX 1	27
APPENDIX 1A	29
APPENDIX 2	31
APPENDIX 3	32
APPENDIX 4	35
ENA Technical Specification 35-2 Issue 6 - 2014	36

## 1.0 SCOPE

This specification covers the technical requirements for three-phase, oil immersed, 66/11.5kV , 33/11.5kV and 33/11.5/6.9kV dual ratio, 50Hz, emergency rated system transformers for use on systems having the 11.5kV neutral earthed directly or through resistance, reactance or arc suppression coil at one or more points.

## 2.0 FOREWORDS

All equipment supplied under this specification will meet the technical requirements of [ENA Technical Specification 35-2, Issue 6, 2014 - Emergency Rated System Transformers 66/20.5kV, 66/11.5kV and 33/11.5kV Delta/Star and Star/Star Connected.](#)

Additional clauses contained within this specification are in addition to the requirements of the standards outlined in ENA Technical Specification 35-2. Where there is any conflict between ENA Technical Specification 35-2 and this document, then this specification shall take precedence.

Manufacturers should consider carefully the implications of arc suppression coil earthing of both 33kV and 11.5kV systems on the insulation requirements of the equipment supplied.

The transformer and its ancillaries shall be designed such that it can continue in operation in times of flood when water levels could reach 1m above the plinth level. All parts below this level shall be sealed to allow submersion. Items which are not suitable for submersion shall be located above this level. Any items that are below the 1m level that are not suitable for submersion shall be listed in Appendix 4 together with the reason for the non-compliance and the extent of damage and rectification needed following subsidence of the flood.

Clause numbers in this specification correspond to clause numbers in ENA Technical Specification 35-2.

## 3.0 DEFINITIONS

Clause 3 of ENA Technical Specification 35-2 applies.

## 4.0 SERVICE CONDITIONS

### 4.2 Normal Service Conditions

The requirements of IEC 60076-1, Clause 4.2 shall apply only at the ONAN rating. The emergency rated condition (CER) shall be based on an ambient air temperature of 5 degrees C unless specified otherwise by the purchaser in the schedule of requirements.

## 5.0 RATINGS

Clause 4 of ENA Technical Specification 35-2 applies with the addition of -

- Dual ratio transformers for which the voltage ratio at no-load, on the principal tap, shall be 33000/11500/6900 V.

For 66//11.5kV transformers the voltage ratio at no load on the principal tap shall be 66000/11 500V.

**Table 1**  
**Standard Values of Rated Power**

<b>ONAN Rated Power in accordance with IEC60076-1 (MVA)</b>	<b>Emergency Rated Power CER (MVA)</b>	<b>Emergency Rated Secondary Current (A)</b>	<b>Switchgear Nominal Rated Current (A)<sup>1</sup></b>
7.5	15	753	800
12	24	1205	1250
20	40	2008	2000
Note 1: The purchaser shall ensure that the switchgear on the 11kV side is adequately rated for the transformer secondary current.			

An extra two rows shall be added to Table 1 to give the Switchgear Nominal Rated Current (A) for when a dual ratio transformer is running on the 33000/6900 V ratio as below:-

<b>ONAN Rated Power in accordance with IEC60076-1 (MVA)</b>	<b>Emergency Rated Power CER (MVA)</b>	<b>Emergency Rated Secondary Current (A)</b>	<b>Switchgear Nominal Rated Current (A)<sup>1</sup></b>
7.5	15	1255	1250
12	24	2008	2000
Note 1: The purchaser shall ensure that the switchgear on the 6.9kV side is adequately rated for the transformer secondary current.			

Transformer ratings larger than 24 MVA emergency rating will not be required for 33/11.5/6.9 kV transformers.

Options are given in Appendix 1 (33/11.5kV) or Appendix 1A (66/11.5kV)

### 5.1.2 Preferred values of rated power

In addition to Clause 5 of ENA Technical Specification 35-2, the manufacturer shall supply with the tender the following graphs

- CER vs. ambient temperature.
- ONAN rating vs ambient temperature.
- CMR vs ambient temperature.

## 6.0 REQUIREMENTS FOR TRANSFORMERS HAVING A TAPPED WINDING

Clause 6 of ENA Technical Specification 35-2 applies. Options are given in Appendix 1. (33/11.5kV) or Appendix 1A (66/11.5kV)

Unless a multi-start tapping winding is employed, all tapings should be made on the outside winding face. Tapings brought out between turns or discs are not acceptable.

### 6.4 - Tapings

For 66/11.5kV transformers the tapping range shall be +9% to -15% in 16 steps of 1.5%.

For 33/11.5kV transformers the tapping range shall be  $\pm 8 \times 1.25\%$  (+/- 10%)

### 6.5 - Short circuit impedance

Unless otherwise specified in Appendix 1A, the short circuit impedance of 66/11.5kV transformers shall be designed to the following

7.5/15MVA on a 15MVA base shall be

Nominal Tap

Max impedance 17.2%

Min impedance 15%

On tap 1 (+9%)

Max impedance 18.1%

Min impedance 14.1%

On tap 17 (-15%)

Max impedance 16.6%

Min impedance 15%

12/24MVA Low Impedance on a 24MVA base shall be

Nominal Tap

Max impedance 19.5%

Min impedance 17%

On tap 1 (+9%)

Max impedance 21%

Min impedance 16%

On tap 17 (-15%)

Max impedance 19%

Min impedance 17%

12/24MVA High Impedance on a 24MVA base shall be  
Nominal Tap  
Max impedance 27%  
Min impedance 24%

On tap 1 (+9%)  
Max impedance 29%  
Min impedance 22.5%

On tap 17 (-15%)  
Max impedance 26.5%  
Min impedance 24.7%

20/40MVA on a 40MVA base shall be  
Nominal Tap  
Max impedance 34%  
Min impedance 30%

On tap 1 (+9%)  
Max impedance 35%  
Min impedance 28%

On tap 17 (-15%)  
Max impedance 33%  
Min impedance 30%

All 33kV impedances shall be as per ENATS 35-2 as specified in Appendix 1

7.5/15 MVA shall be impedance envelope 1.a.  
12/24MVA shall be either impedance envelope 1.b. or 1.c.  
20/40MVA shall be 1.f.

#### **6.6 - Load loss and temperature rise**

The requirements of ENATS 35-2 clause 6.6 shall apply.

Temperature rise test shall be carried out in accordance with Clause 11.1.3 of ENA technical spec 35-2.

Transformers offered by manufacturers are required to satisfy the eco-design regulations 2009/125/EC and to conform to the requirements associated with Commission Regulation 548/201 with regard to small, medium and large power transformers.



The energy performance of a transformer at its equivalent CMR rating shall comply with the maximum allowed values of load losses and no load losses or peak efficiency index (PEI) for Tier 1 stated in the appropriate tables of Annex 1 of the eco-design regulations. After the date July 2021 all transformers must comply with Tier 2 losses as per the eco-design regulations 2009/125/EC

## 7.0 CONNECTION AND PHASE DISPLACEMENT SYMBOLS FOR 3 PHASE TRANSFORMERS

Clause 7 of ENA Technical Specification 35-2 applies. Options are given in Appendix 1 (33/11.5kV) or Appendix 1A (66/11.5kV).

## 8.0 RATING PLATES

Clause 8 of ENA Technical Specification 35-2 applies.

Rated power shall be shown on the rating plate as below.

Ambient Temp (degrees C)	Rated Power (MVA)		
	ONAN	CER	CMR
5	AA	BA	CA
10	AB	BB	CB
20	AC	BC	CC
30	AD	BD	CD
40	AE	BE	CE

## 9.0 SAFETY, ENVIRONMENTAL AND OTHER REQUIREMENTS

Clause 9 of ENA Technical Specification 35-2 applies.

All windings shall be of copper.

The maximum flux density in any part of the core or shields shall not exceed 1.65T (tesla).

The line-to-neutral output voltage wave of Star/Star connected transformers shall not introduce more than 0.5% third harmonic component when the transformer is excited at 33kV or 66kV (as relevant) on the normal tapping.

The transformer, coolers, tapchanger and ancillaries shall be designed so that water collection points/traps are avoided.

The transformers shall be designed to withstand without damage external short circuits as specified in BS EN 60076-5, taking the 33kV short circuit apparent power of the system (clause 3.2.2.4) as 1000 MVA and that for the 66kV system as 3000 MVA unless otherwise specified. The duration of the short circuit (clause 4.1.3) shall be 3 seconds.

### 9.3 Oil preservation system

The oil preservation system shall be free breathing with a maintenance free desiccant (silica gel) or self-dehydrating breather as determined by the manufacturer. Details of the system used shall be provided at time of tender for approval. Although the device is maintenance free it shall be positioned so that it is accessible from ground level for repair/maintenance and situated 1m from the ground to prevent damage during times of flooding.

### 9.4 Insulating oil

The manufacturer will provide oil in accordance with IEC 60296 high grade inhibited oil.

The oil offered shall have the following stand out properties.

Property	Test Method	Value
Dielectric Dissipation Factor at 90 °C and 20 °C	IEC 60247	Less than 0.0025
Flash Point (°C)	ISO 2719 ASTM D93	>170
Total Sulphur Content (ppm)	IP 373 ISO14596	Non-detectable (less than 1 ppm)
Breakdown Voltage (kV)	IEC 60156	>50kV (Untreated)
Breakdown Voltage (kV)	IEC 60156	>70kV (Treated)
Corrosive Sulphur	DIN 51353 or ASTM D1275B	Non corrosive
PCB (ppm)	IEC 61619	Non-detectable (less than 1 ppm)
Water Content (ppm)	IEC 60814	<15

The oil used needs to be identified at time of tender and on the name plate for future reference.

## 10.0 TOLERANCES

Clause 10 of ENA Technical Specification 35-2 applies.

## 11.0 TESTS

Clause 11 of ENA Technical Specification 35-2 applies.

For 33kV and 66kV rated transformers, the Insulation Levels in Table 2 shall apply

**Table 2**  
**Insulation Levels**

Highest voltage for equipment Um (r.m.s.) kV	Nominal system voltage (kV)	Rated lightning impulse voltage (LI) kV (peak)	50Hz withstand voltage kV (r.m.s)
12	11	95	28
36	33	170	70
72	66	325	140

The following additional tests are also required:-

### 11.1.2 Routine Tests

- i. Measurement of positive sequence impedance at every tapping position
- ii. Correct functioning of the tap-changer and driving mechanism
- iii. SFRA shall be carried out in the factory before shipping and as the first test on site once the transformer has been landed on its plinth.
- iv. For all star star connected transformers zero sequence impedance tests shall be carried out on all units

### 11.1.3 Type Tests

Where a tank attached radiator design is offered the OFAF type tests shall be undertaken twice, once with the radiator panels attached to the tank and once with the radiators configured in a separate bank.

### 11.1.4 Special Tests

The cost for a short circuit test in accordance with BS EN 60076-5 shall be provided at the time of tender, when a decision shall be made as to whether the test is required.

## 11.6 Measurement of zero-sequence impedance

On star/star transformers, measurements of zero-sequence impedance shall be taken with the current specified in Table 5 of ENA Technical Specification 35-2 in the LV neutral and the HV winding open circuited. The zero-sequence impedance in ohms/phase shall lie within the limits in table 3.

**Table 3**  
**Zero Phase Sequence Impedance**

Emergency Rated Power (MVA)	Zero Phase Sequence Impedance (ohms/phase)	LV Neutral Current (A)
15	8 to 12	400
24	6 to 10	600
40	3 to 8	1000

#### 11.14 Determination of Sound Levels

The ONAN Sound Power Levels given in Clause 11.14 Table 4 of ENA Technical Specification 35-2 shall apply, but cooler sound power levels (dBA), shall each be reduced by 3dBA from the ENA Technical Specification 35-2 figures to new Western Power Distribution figures listed in Table 4.

**Table 4**  
**Maximum Noise Level**

<b>Rated Emergency Power (MVA)</b>	<b>ONAN Rating Sound Power Level (dBA)</b>	<b>CER Rating Sound Power Level (dBA)</b>	<b>WPD CER Rating Sound Power Level (dBA)</b>
15	63	81	78
24	65	83	80
40	68	85	82

#### 11.15 Frequency Response Analysis

**FRA** shall be carried out on the transformer before leaving the manufacturer's works and repeated again at site following assembly. The instrumentation leads, etc. shall be arranged so that the conditions of test on site are as close as possible to the conditions of test in the manufacturer's works.

#### 11.18 Site Tests

The site tests (a) to (n) listed in Clause 11.18 of ENA Technical Specification 35-2 and the following tests shall be carried out by the manufacturer at the time of commissioning.

1. Core Earth Test
2. For all CT's
  - a. DC resistance
  - b. Flick test
  - c. Magnetisation Curves

The cost of providing the FRA tests shall be included in the overall price, but identified separately at the time of tender.

### 12.0 ELECTROMAGNETIC COMPATIBILITY (EMC)

Clause 11 of ENA Technical Specification 35-2 applies.

## **14.0 TRANSFORMER DETAILS**

Clause 14 of ENA Technical Specification 35-2 applies.

### **14.4 Limiting Dimensions**

**14.3.1 Separate Cooler Bank Arrangement** - as ENA Technical Specification 35-2 applies.

### **14.7 Tank Attached Cooler Arrangement**

An arrangement having flanged tank attached radiators, which is designed to permit simple conversion, either at time of initial installation or at a later date, to a separate radiator bank arrangement using the existing components save for additional pipework, expansion joints and supports.

This arrangement shall meet all requirements of this specification including the requirements of Clause 14.3.1 of ENA Technical Specification 35-2 when configured as a separate radiator bank arrangement.

Flanges between radiator panels and the tank shall be equipped with valves.

The same pump(s), radiator panels and conservator shall be used when converting to separate radiator bank arrangement, noting height, hydraulic and thermal issues.

The Contractor must have fully designed the conversion arrangement and type tested it they must provide full manufacturing, arrangement and assembly drawings to permit WPD to undertake later conversion without further need for reference to the Contractor.

### **14.8 Plinth**


The transformer and cooler footprint shall be at least 50mm from the edge of the plinth.

## **15.0 CONSTRUCTION DETAILS**

Clause 15 of ENA Technical Specification 35-2 applies.

## 15.1 Tanks and Covers

A socket for insertion of a work positioning restraining post (RidgeGear SSP Sub-Station fall arrest post) shall be provided as near the centre of the transformer lid as practicable. This shall be as detailed in the Figure below.



## 15.3 Terminals

### 15.3.1 The HV connection shall be either:-

Three outdoor bushings in accordance with IEC 60137 and Table 5 of ENA Technical Specification 35-2 mounted on turrets. For 66kV rated transformers the following requirements apply for Table 5.

**Table 8**  
**Outdoor bushing details**

Voltage (kV)	Live Metal to Earth Flashover distance (mm)	Air end creepage distance(mm)	Stem diameter (mm)	Stem length (mm)
72.5	700	1820	20 or 30	125

Accommodation for two sets of protective current transformers to BS EN 60044-1,

Set 1 15VA 5P10, ratio 300/1 for 15MVA, 400/1 for 24MVA, 800/1 for 40MVA

Set 2 nearest the windings 800/1 class PX

For transformers with tank attached or separate cooler bank arrangements the CT's may be located in the main tank top oil, provided they are readily accessible for replacement via an access cover. The necessary accommodation space, 66kV or 33kV insulation and suitable external terminals must always be provided, independent of whether the CT's themselves are supplied by the manufacturer.

The volume of oil that needs to be removed to change the CT's shall be given in Appendix 3.

The supply of two sets of current transformers as specified above shall be included in the offer. The manufacturer shall supply a full specification including physical dimensions of all CTs installed.

Limiting dimensions for each current transformer are:

Inside Diameter	75 mm minimum
Outside Diameter	230 mm maximum
Length	55 mm maximum

Protective current transformers provided shall be wired to terminal blocks in the control cubicle.

The HV bushings shall be wired to allow for Neutral Voltage Displacement protection. This needs to be wired back to the control kiosk. The same arrangement needs to be made available for separable connectors and the LV terminations.


Surge diverter brackets shall be provided. The bracket should have a 14mm diameter hole to accommodate a surge diverter with a single bolt fixing and suitable to accommodate a surge diverter with a length of up to 600mm (33kV) when the busbar connection is horizontal. For 66kV assume use of ABB PEXLIM Q YV072 housing (736mm) when the busbar connection is horizontal. Or alternatively for 66kV assume use of TE Energy PCA 3-72 housing (1085mm) when busbar connection is horizontal.

The surge diverter brackets shall be fitted to accommodate busbars being connected from the HV side of the transformer, however it shall be possible to fit the surge diverter brackets on the opposite side of the bushing to accommodate the HV busbars being landed from the LV side across the top of the transformer. Use of angled brackets is permitted to gain clearance when busbars run in a descending manor from transformer bushings to the next associated structure.

Facility shall be available to fit a single arc gap of 305mm on each 33kV bushing and 540mm on each 66kV bushing, but as it is intended to use surge diverters these shall not be fitted.

The layout of the LV cable box and HV bushings shall be as shown below.

The HV bushings shall not be on the same physical side of the transformer as the LV separable connectors.



It is accepted that when bushings are replaced with cable boxes and any associated disconnecting chambers, some component parts may need to be changed, but these should be kept to a minimum.

Or

Cable connected transformers having a voltage rating of 66 kV, shall have their cables terminated using inner cone Pfisterer Size 4 separable connectors the separable connectors shall have individual phase chambers.


Where inner cone separable connectors are fitted to transformers rated 20MVA and above, a disconnecting chamber shall be provided. Both inner cone separable connector chambers and disconnecting chambers shall be of phase isolated design.

The inner cone separable connector chambers shall be filled with insulating oil complying with the requirements of BS 148 (2009). The oil level shall be maintained from the main conservator by means of a connecting pipe of 25 mm diameter to the highest point in the chamber. This connection shall be controlled by a suitable valve, and shall ensure that any gas leaving the chamber will pass through the gas and oil actuated relay specified. A barrier shall be provided on both sides of the disconnecting chamber to prevent oil used for filling the chamber from entering the cable box or from communicating with the oil in the transformer, other than through the equalising pipework to the conservator. It shall be necessary to remove only part of the oil in the chamber itself when making the necessary testing connections.

An approved drain/filter valve shall be provided at the lowest point and a filter valve shall be fitted at the top of the chamber.



Each chamber shall have two Pfisterer size 4 inner cone separable connectors; one connector shall be installed in the upward direction and the other in the downward direction, see pictures below for typical layout. The incoming cable entries shall be vertical from below; the upper inner cone connector shall be voltage-proof sealed with a dummy connector.



The inner cone separable connector chambers shall have flanged joints with gaskets and provided with bolted access covers. Gaskets shall be below oil level at a temperature of minus 10°C.

The inner cone separable connector chambers and associated disconnecting chambers shall permit either the transformer or the cable to be subjected to the high voltage test specified in their own Contract documents. The upper inner cone connector provides for mounting a temporary bushing for this purpose. Subject to the approval of the Purchaser, it will be permissible to use such a bushing for factory tests on the transformer in lieu of the cable.

When required by the Purchaser, inner cone separable connectors and their associated chambers shall be tested in accordance with the relevant clauses of IEC 60840 and DIN VDE 0276 05.

The inner cone separable connectors, bushings and their mounting arrangements shall withstand the thermal and dynamic effects of short-circuit currents of the associated transformer, as specified in IEC 60076.

The inner cone separable connector chambers shall, in addition to their own specified requirements and the specified 'when laid and jointed' test requirements for the associated cables, be capable of withstanding for 60 minutes, between phases and between phases to earth, the following test voltage: -

Either: -

- (i) 1.7U<sub>0</sub> kV, ac generated by series resonance at or about 50Hz the actual test frequency will depend on the length and CSA of the cable.

Where U<sub>0</sub> = the power frequency voltage between phase and earth.

Or

- (ii) An AC voltage test at power frequency. This test shall be for 5 minutes with the phase-to-phase voltage (U) applied between the conductor and the metallic screen.

Note: - During these tests, the links between the transformer/reactor and cable connections will be withdrawn and the windings earthed.

A supporting bracket shall be provided on the side of the transformer to support the HV cables and pre-drilled to mount Ellis Patent twin bolt fixing Atlas cable cleats. The Ellis Patent Atlas cable cleats shall be commensurate for the correct size of cable required for the transformer in question. Unless otherwise agreed, this bracket shall be mounted no more than 1 metre below the gland plate. The bracket shall be positioned in such a way that when the Atlas cable cleats are fitted, the cables shall pass through the centre of the cleat and enter straight into the base of the inner cone separable connector housing. The Ellis Patent, Atlas cable cleats will not be supplied with the transformer.

Cabling and jointing within the inner cone separable connector chambers will be carried out under a separate contract.

Cable connected transformers having a voltage rating of 33 kV, shall have their cables terminated using outer cone, bolted, interface C separable connector bushings to EN 50181, rated 36kV 1250A continuous (Euromold type M400 AR-4, see drawing SD 567 E, unless otherwise agreed in writing at time of tender) mounted on the vertical face of the tank wall to permit cable connection from below. Alternative makes may be offered but shall not be provided unless accepted in writing by WPD. A weather shield shall be provided over these bushings, having sufficient clearance to house one separable connector type M440 TB/G, for the respective cable size, with dead end plug and cap, plus an additional 100 mm air clearance. The weather shield shall provide for access to unplug the separable connectors by removal of the front face of the weather shield and such bottom mounted parts as necessary. These removable components shall be fitted with handles as required and no single part shall weigh more than 25kg. Materials surrounding the single core cable entries shall be nonferrous to avoid eddy current heating effects and shall avoid a shorted turn being created by the tank wall. If the weather shield is unsuitable to carry the weight of a person weighing 150kg, suitable warning labels shall be applied to the front and top.

The phase markings shall be as detailed in Clause 13.3 with the HV and LV connections on the same side of the tank.

A supporting bracket shall be provided on the side of the transformer to support the 33kV cables and pre-drilled to mount Ellis Patent twin bolt fixing Atlas cable cleats type AR2-A13. Unless otherwise agreed, this bracket shall be mounted no more than 1 metre below the bushing. The bracket is likely to need bracing to either the tank wall or to the ground, it is preferred that the bracing be to the tank wall. The bracket shall be positioned such that when the Atlas cable cleats are fitted, the cables shall pass through the centre of the cleat and enter straight into the base of the connector housing. The Ellis Patent, Atlas cable cleats will not be supplied with the transformer.

A bolt on oil filled disconnecting chamber shall be provided as detailed in Clause 15.3 of ENA Technical Specification 35-2.

Two sets of current transformers as detailed in 15.3.1 of this specification, mounted on suitable bushings to facilitate replacement, and easily accessible through a suitable access plate in the tank lid shall be provided.

Protective current transformers provided shall be wired to terminal blocks in the control cubicle.

The HV bushings or terminals shall include a capacitor tap for neutral voltage displacement protection purposes. The capacitance shall be as follows

- 66kV outdoor bushings 260pF
- 33kV outdoor bushings 76pF
- C Type Euromold bushings 28pF

To match the NVD relay, these arrangements shall be wired to a terminal within the MK ready for WPD to connect to this shall form on board NVD protection as specified in the schedule of requirements.

Minimum oil level : - 12 kV : 40 mm  
 - 24 kV : 50 mm  
 - 36 kV : 70 mm

**DESCRIPTION**

- ① **SHIPPING CAP**  
Supplied with the bushing, the cap provides mechanical protection for the mating interface. This cap should not be considered as an electrical dead-ending device. Use a (K)(M)400DR-B or (K)(M)400DR-B/G dead-end receptacle for this purpose.
- ② **THREADED CONTACT**  
Provided with a thread which engages the clamping screw.
- ③ **MATING INTERFACE**  
This interface accepts the 400 series mating part with an interference fit that prevents moisture or contaminant from entering.
- ④ **FIXING FLANGE**  
Epoxy resin flange also contains screen earth connection.
- ⑤ **BUSHING SHANK**  
Epoxy resin insulation suitable for operation under oil fluid.
- ⑥ **BUSHING STEM**  
The copper stem is turned down to a threaded rod to accept the equipment's or cable connection.
- ⑦ **TWO LOCKNUTS M16x2**  
For the internal connection. These nuts are supplied with the bushing (Except for bulk packaging).

**ELECTRIAL RATINGS**

Bushing type	400AR-4	K400AR-4	M400AR-4
<b>VOLTAGE *</b>			
System	6/10 kV (12 kV max.)	12/20 kV (24 kV max.)	18/30 kV (36 kV max.)
Partial Discharge Extinction** (5 pC sensitivity)	11 kV	21 kV	31 kV
Impulse (1,2 x 50 μs)	75 kV	125 kV	170 kV
Industrial Power Frequency** (50 Hz - 1 minute)	35 kV	55 kV	75 kV
<b>CURRENT</b>			
Continuous	1250 A	1250 A	1250 A
Overload (8 hrs in 24 hr period)	1500 A	1500 A	1500 A
Short circuit: RMS symm. 1 sec. Peak asymm.	>70 kA >125 kA	>70 kA >125 kA	>70 kA >125 kA

\* Ratings are based on IEC standards and do not reflect maximum withstand levels. For compliance with other standards, refer to our local representative.  
 \*\* These tests are applied to 100 % of production.

**Equipment bushing (CENELEC type C interface)**  
**Type (K)(M)400AR-4**

BL/18 August 2000  
 Rev. 0  
**SD 567/E**

### 15.3.5 HV Neutral

The 66kV and 33kV neutral point of each Star/Star connected transformer shall be made readily available. A flange to BS2562 facing 'C' with its major axis horizontal shall be provided on the tank to accept one of the following.

- i. A blanking plate
- ii. An outdoor bushing in accordance with IEC 60137 and Table 5 of this specification and ENA Technical Specification 35-2

A bracket shall be provided near the base of the bushing to enable WPD to fit a surge diverter.

Facility shall be available to fit a single arc gap of 305mm for 33kV transformers and 540mm for 66kV transformers, but as it is intended to use surge diverters this shall not be fitted.

### 15.3.6 LV Terminations

15 and 24 MVA - Four separable connector bushings Euromold type M400 AR-4, 1250A mounted on the vertical face of the tank wall to permit cable connection from below. A weather shield shall be provided over these bushings, having sufficient clearance to house two separable connectors type M440 TB/G with one connecting plug and a dead end plug and cap plus an additional 100 mm air clearance.

40 MVA transformers - 9 + 1 separable connector bushings Euromold type M400 AR-4, 1250A mounted on the vertical face of the tank wall to permit cable connection from below. A weather shield shall be provided over these bushings, having sufficient clearance to house one separable connectors type K440 TB/G with one connecting plug and a dead end plug and cap plus an additional 100 mm air clearance.

Alternative makes of separable connectors may be offered, but shall not be provided unless accepted in writing by WPD.

If specified in Appendix 1 (33/11.5kV) or Appendix 1A (66/11.5kV) - Schedule of Requirements, an oil filled disconnecting chamber shall be provided as detailed in Clause 13.3 of ENA Technical Specification 35-2 to disconnect the 11/6.6 kV windings from the outgoing cable.

A supporting bracket shall be provided on the side of the transformer to support the 11kV cables and pre-drilled to mount Ellis Patent twin bolt fixing Atlas cable cleats type AR2-A13. Unless otherwise agreed, this bracket shall be mounted no more than 1 metre below the bushing. The bracket is likely to need bracing to either the tank wall or to the ground, it is preferred that the bracing be to the tank wall. The bracket shall be positioned such that when the Atlas cable cleats are fitted, the cables shall pass through the centre of the cleat and enter straight into the base of the connector housing. The Ellis Patent, Atlas cable cleats will not be supplied with the transformer.

The weather shield shall provide for access to unplug the separable connectors by removal of the front face of the weather shield and such bottom mounted parts as necessary. These removable components shall be fitted with handles as required and no single part shall weigh more than 25kg. Materials surrounding the single core cable entries shall be nonferrous to avoid eddy current heating effects and shall avoid a shorted turn being created by the tank wall. If the weather shield is unsuitable to carry the weight of a person weighing 150kg, suitable warning labels shall be applied to the front and top.

It is a requirement to construct a bund wall around the transformer to contain an oil spillage. In constructing a bund it is necessary to fix ducts around all cables to above the height of the bund wall (up to 600 mm). It shall be possible to terminate and fit cables onto the bushings with this duct in place.

If and when requested LV outdoor bushings can be supplied and will require approval from WPD prior to these being used. These bushings shall be in accordance with IEC 60137 and be of composite construction like the HV bushings.

#### **15.3.7 LV Neutral**

A bracket, suitable for supporting a weatherproof outdoor neutral current transformer fitted around the neutral cable, is required vertically below the neutral cable connector.

#### **15.3.8 Unit Auxiliary Transformer**

When specified in Appendix 1 (33/11.5kV) or Appendix 1A (66/11.5kV), an auxiliary transformer shall be supplied. It shall be oil filled, 50kVA, 11,000 / 415V, 3 phase, 50Hz, 4.75% impedance, Dyn11 and as specified in Clause 15.3.58 of ENA Technical Specification 35-2. The auxiliary transformer shall be supplied via full range fuses that are situated in a chamber separate from the main transformer tank.

The LV terminations of the auxiliary transformer shall be isolatable via a ganged switchfuse and have clearance from the bottom of the switchfuse termination to the gland plate of 200mm for 50kVA and 300mm for the 100kVA option. The operating handle must be lockable in the on and off position.

When no auxiliary transformer is specified the flange arrangement specified in Clause 15.3.8 of ENA Technical Specification 35-2 shall be provided, but fitted with a blanking plate.

#### **15.4 On-load Tap-changer**

Clause 15.4 of ENA Technical Specification 35-2 applies.

The tap-changer shall be capable of bi-directional power flow for its full rating.

The possibility of overrunning the mechanism at each end of the voltage range shall be prevented by means of limit switches and mechanical stops.

A mechanically operated indicator shall show the number of the tap position in use. The numbering of the tap position shall be such that an increase in number corresponds to an increase in voltage of the lower voltage side of the transformer.

When the tapchanger is switched to local operation, automatic or supervisory operation shall be inhibited.

Equipment shall be designed for minimum maintenance. Diagnostic testing and inspection shall be required at intervals of not less than six years. In any event, the switches and oil of the diverter switch and selector switch compartments shall be capable of withstanding 300,000 operations at maximum rated through current without requiring attention.

The manufacturer shall advise at time of Tender the maintenance requirements for the tapchanger offered, including current costs of parts and an estimate of man hours.

For transformers with separate radiator banks and an external flange mounted tapchanger, the tapchanger shall be positioned on one of the longest sides of the tank and not on either end, so access to the tapchanger shall not be inhibited by oil pipes to the radiators, independent of which way the transformer is handed. The tapchanger shall be of bolt on design. Where available the preference would be for vacuum bolt on technology that has passed a full type test as per IEC 60214-1.

The self-dehydrating breather shall be accessible from ground level to facilitate maintenance.

Tapchanger control shall be to WPD schematics

SPC11TCC2 shall apply to WPD Midlands and WPD South West

SPC11TCC1 shall apply for WPD South Wales.

## 15.5 Clearances to exposed conductors

Clause 15.5 of ENA Technical Specification 35-2 applies except in paragraph (ii) 2580mm shall be substituted in place of 2400mm,

For 66kV transformers the following requirements apply for Table 10 External Air Clearances.

**Table 10**  
**External Air Clearances**

<b>Highest voltage for equipment</b>	<b>72.5kV (mm)</b>	<b>36kV (mm)</b>
Between live metal including neutral, and earth	700	500
Between live metal of different phases and phase to neutral	780	430
From live metal to any oil pipe work including conservator	700	500

### 15.6.1 Conservator

In addition to the requirements of Clause 15.6.1 of ENA Technical Specification 35-2 the conservator shall have a minimum volume of 10% of the total transformer and cooler oil content.

### 15.6.2 Cooling Plant

In addition to the requirements of Clause 15.6.2 of ENA Technical Specification 35-2 a valve shall be provided between the pump and bottom header of the cooler bank to facilitate the removal of the pump.

Drain plugs shall be fitted for draining each section of the cooler.

Air release plugs shall be provided where necessary to facilitate oil fillings.

Facilities shall be made to allow handing of cooler banks on either end of the transformer.

### 15.6.3 Gas and oil actuated Relays

For checking the operation and continuity of the electrical contacts each relay shall be provided with an internal injection nozzle associated with a test cock (to be operated standing at ground level and with facilities for locking in the closed position) to take a flexible pipe connection for air and oil injection.

Gas and oil actuated relays with magnetic reed contacts are not permitted. Minimum flow rates for gas and oil relays shall be 1.2m/s.

### 15.6.4 Pressure Relief Device

The pressure relief device shall be unaffected by the starting or stopping of the pump.

The device shall be flange mounted, preferably on the side of the tank. If it is not possible to mount the device on the side of the tank, and it is mounted on the cover means shall be provided to prevent any gas collection in the chamber under the valve disc.

The outer end of the pipework shall be protected from ingress of vermin etc by a fine mesh grid, but the mesh shall not facilitate the formation of ice or paint spray to seal the outlet.

An approved, sealed, normally open, weatherproof trip switch shall be provided, cabled to the marshalling cubicle. Means shall be provided whereby the switch reset button or arm can be operated without removing the outer pipework.

### 15.6.5 Winding Temperature Indicator

ENATS 35-2 clause 15.6.5 applies.

Each transformer shall be provided with an approved device indicating the maximum winding temperature) a winding temperature indicator and associated current transformer. The winding temperature indicator shall be of an electronic design for example the Ashridge 852 Plus.

Means shall be provided, external to the winding temperature indicator case, for checking the operation and setting of the contacts. Means shall be provided with facilities to prevent unauthorized interference. The temperature indicator shall have a range of 30°C to 150°C. The design of the indicators, the components contained therein, any capillaries and their connections, other associated equipment and the mounting arrangements shall be such that the equipment will not sustain damage or mal-operation due to vibration in service. Anti-vibration mountings shall preferably be integral with the indicator case.

The indicator shall have three sets of independently adjustable contacts having the following purpose and characteristics:

**(i) Cooler Control**

Adjustable setting 50°C to 100°C (5°C maximum steps)

Adjustable differential 15°C to 30°C

**(ii) Alarm**

Adjustable setting 80°C to 150°C (5°C maximum steps)

Fixed differential of not more than 10°C

**(iii) Trip**

Adjustable setting 80°C to 150°C (5°C maximum steps)

Fixed differential of not more than 10°C

Dial type indicators shall have contacts that are adjustable to a scale and that are accessible on removal of the cover.

The winding temperature indicator shall be arranged to replicate the “hottest” winding.

**15.6.6 Current Transformers**

All CT's shall be provided with a 40 amp primary injection test loop. The test loops shall be terminated in a terminal box either mounted on the turret (if outdoor bushing are used), or on the tank side.

The voltage compounding current transformer shall be rated at not less than 15VA Class 0.5S.

All CT's must be positioned such that they can be readily replaced through an inspection plate with the transformer oil level still above the windings.

**15.6.7 Other Fittings**

- (v) The oil sampling device shall be between 200 and 300mm above plinth height. Details of this device are to be supplied at the time of tender.



- (vii) In addition to the requirement of Clause 15.6.7 (vii) identical earthing tags shall be provided on the main tank, as close as possible to, and below, each surge diverter mounting point (HV side only).

Facility shall be provided to support 50mm x 4mm copper earth tape horizontally between the 3 earth tags mentioned above and vertically from this horizontal run to ground level at a point on the tank as close to the central tag as possible. For security reasons (copper theft) it shall be possible to securely bolt the earth tape to the transformer using stainless M12 shear head bolts at a maximum spacing of 300mm.

The earthing tags shall have a blanking plate fitted over them before painting, which can easily be removed, on site, leaving a clean face for connection of the earth.

- (xii) The transformer lid shall be bonded to the main tank with 200mm<sup>2</sup> copper at a point as close as possible to the central earth tag mentioned above.

Ladder tie off points shall be provided where there is a need to access the lid or other lid mounted apparatus.

All external fixings and fastenings shall be stainless steel with anti-galling paste or coating applied, washers and nuts shall be of a different grade of stainless to prevent galling

## 15.7 **Marshalling and/or Control Box**

The marshalling and/or Control box can be mounted on either the cooler supporting frame work or the tank wall.

The top of any marshalling / control box shall be less than 2.2m above ground level. Attention is drawn to the requirement given in Clause 2 of this specification for equipment being able to withstand flood water to 1m above plinth level.

Terminal boards shall preferably be Klippon type RSF1 except for telecontrols which shall be type SAKR. If space is a premium consideration shall be given to the use of RSF3 terminals, but all AC supplies shall be RSF1. All terminations shall be made off with hook blade crimps and all wiring shall be Steel Wire Armoured double insulated cable.

A RCD controlled 13A socket (MK Masterseal or equivalent) shall be fitted to the outside of the Marshalling/Control box.

Cooler Control circuitry shall be as WPD schematics

SPC 201 for WPD Midlands and WPD South West,

PSD0890 for WPD South Wales.

Telecontrol voltage shall be as follows

WPD Midlands and South West new build substations shall be 48V.

WPD South Wales shall be 24V.

There will be existing sites that will need the voltage to be advised at the time of order.

## **16.0 DOCUMENTATION**

Clause 16 of ENA Technical Specification 35-2 applies.

### **16.1 Format of electronic drawing shall be Autocad DWG.**

All Detailed Project/Contract Specific Drawings including the physical Transformer GA drawing drawings shall be supplied within 2 months and no longer than 3 months of receipt of order. Indicative layout drawings shall be issued within 1 month to enable WPD to commence civil works.

All drawings shall be approved by WPD before manufacture commences. WPD approval shall take no longer than 2 weeks after drawings are sent to the relevant design engineer.

After construction and commissioning the manufacturer shall incorporate any alterations in these drawings, which have occurred during site work and these shall be completed within 2 months of the completion of site works. All contract drawings shall make reference to site specific names.

A copy of the transformer test certificate shall also be provided in .pdf format.

## **17.0 PROGRAMME AND PROGRESS INFORMATION**

The manufacturer shall provide within one month of the date of WPD's order a detailed manufacturing programme for each transformer. These copies shall be sent to the WPD nominated Engineer. The programme shall include delivery date to site, erection, commissioning test and handover dates. This programme shall then be updated on the first working day of each month and an update provided to the Engineer named. In the event of changes to the programme, detail should be provided on the reason for the change verbally and backed up in writing.

## **18.0 DELIVERY AND ERECTION**

18.1 The manufacturer shall deliver the transformer to site, off load, carry out all site erection onto prepared foundations, and undertake all site tests specified in Clause 11.13 of this specification. Site erection staff shall be proficient in English. Two copies of all site test results shall be provided to WPD prior to handover.

18.2 All the above work will be carried out in co-operation with the WPD's staff.

**EXAMPLE OF SCHEDULE OF REQUIREMENTS FOR EMERGENCY RATED SYSTEM TRANSFORMERS: 33/11.5KV SEE PURCHASING CATALOGUE FOR CURRENT VERSION OF APPENDIX 1 FOR USE AND FLOW CHART ON PROCESS OF COMPLETING AND LIST OF SHOPS CODES**

(To be completed by Purchaser)

\* Purchaser to delete as appropriate

Item	Clause	Description	
1	1.2.2	Ambient temperature for Emergency Rating °C	* 5
2	4.1	Rated power at Emergency Rating MVA HV Nominal Voltage kV LV Nominal Voltage kV	15 / 24 / 40 33            33 or 11.5           11.5/6.9
	5.4	Tap range	* $\pm 8 \times 1.25\%$ (+/- 10%) +4 x 1.43% / -12 x 1.43% (+5.72% - 17.16%)
4	5.4	Category of Tapping Voltage Variation  Where CbVV is selected, provide tap position for changeover between CFVV and VFVV Tap Number	*CFVV
5	5.5	Impedance envelope for 7.5/15MVA Impedance envelope for 12/24MVA Impedance envelope for 20/40MVA	*1 (a) 1 (b) / 1 (c) 1 (f)
6	5.6	Loss Capitalization Values (i) No-load Loss                    £/kW (ii) Load Loss at 50% CER rating £/kW  OR Maximum Guaranteed Losses in accordance with 5.6 (i) No-load Loss                    W (ii) Load Loss at 50% CER rating    W	£4000 £350
7	6	Vector group (add phase displacement number)	* Dyn11 YNyn0
8	6	Vector Links required  If yes, alternative vector group	*No
9	8.1	Neutral conductor and terminal intended to carry load	No
10	8.3	Generator transformer load rejection per 8.3	* No
11	10.1.1	FRA test required at works and on site	* Yes Cost to be advised at time of tender
12	10.1.3	Short circuit test required	* No Cost to be advised at time of tender

Item	Clause	Description	
13	12.4.1 12.4.3	Separate cooler bank required Compact Cooler Arrangement Height limitation mm Valve & blanking plates required at alternative oil inlet	* Yes / No * Yes / No * 4880 / 4270 * Yes
14	12.4.2	Anti-vibration mountings required (Main TX)	* Yes
15	12.5	Auxiliary supply voltage	* 400 V 3 ph / 230 V 1ph
16	13.2	Finish colour required	Dark Admiralty Grey unless otherwise approved
17	13.3	Position of cable boxes	* Yes / No
18	13.3.1	HV terminal arrangement NVD capacitor taps required NVD capacitance if required pF  Surge arresters required Brackets for surge arresters required	* (iv) / (v) * Yes / No * C Type bushings 28pF Outdoor bushings 76pF* No * Yes / No
19	13.3.2	HVN terminal arrangement	* (i) / (ii)
20	13.3.3	LV Terminal arrangement  Number and size of single core cables to be terminated LV cable link disconnecting chamber required	*separable connectors – see Clause 13.3.3 for details   *Yes / No
21	13.3.4	LVN terminal arrangement Number and size of single core cable to be terminated LVN current transformer(s) required Details of LVN current transformer(s)	* (ii)  * No – Mounting bracket only required
22	13.3.5	Auxiliary Transformer required	* Yes / No
23	13.4.1	Max / min tap position indicator required	* No
24	13.6.5	Winding temperature indicator or sensor Output required from sensor Winding temperature indicator type Second WTI or sensor required Electronic WTI d.c. supply voltage Minimum (V) Maximum (V)	* Indicator / Sensor  * Dial / Electronic * No
25	13.6.6	Second voltage compounding CT required	* No, but space for a second one shall be provided.

**EXAMPLE OF SCHEDULE OF REQUIREMENTS FOR EMERGENCY RATED SYSTEM TRANSFORMERS: 66/11.5KV PLEASE SEE PURCHASING CATALOGUE FOR UP TO DATE VERSION OF APPENDIX 1A**

(To be completed by Purchaser)

\* Purchaser to delete as appropriate

Item	Clause	Description	
1	1.2.2	Ambient temperature for Emergency Rating °C	* 5
2	4.1	Rated power at Emergency Rating MVA HV Nominal Voltage kV LV Nominal Voltage kV	15 / 24 / 40 66 11.5
	5.4	Tap range	+9% to -15% 16 steps of 1.5% Other tapping ranges will be considered
4	5.4	Category of Tapping Voltage Variation  Where CbVV is selected, provide tap position for changeover between CFVV and VFVV Tap Number	CFVV
5	5.5	Impedance envelope for 12/24MVA  Other ratings - Impedance envelope for other ratings -see clause 5.5 unless otherwise stated here	"clause (5.5) / other
6	5.6	Loss Capitalization Values (i) No-load Loss £/kW (ii) Load Loss at 50% CER rating £/kW OR Maximum Guaranteed Losses in accordance with 5.6 (i) No-load Loss W (ii) Load Loss at 50% CER rating W	£4000 £500
7	6	Vector group (add phase displacement number)	* Dyn11 YNyn0
8	6	Vector Links required  If yes, alternative vector group	No
9	8.1	Neutral conductor and terminal intended to carry load	No
10	8.3	Generator transformer load rejection per 8.3	No
11	10.1.1	FRA test required at works and on site	Yes Cost to be advised at time of tender
12	10.1.3	Short circuit test required	No but cost to be advised at time of tender

Item	Clause	Description	
13	12.4.1 12.4.3	Separate cooler bank required Compact Cooler Arrangement Height limitation mm Valve & blanking plates required at alternative oil inlet	* Yes / No * Yes / No * 4880 / 4270 Yes
14	12.4.2	Anti-vibration mountings required (Main TX)	Yes
15	12.5	Auxiliary supply voltage	400 V 3 ph / 230 V 1ph
16	13.2	Finish colour required	Dark Admiralty Grey unless otherwise approved
17	13.3	Position of cable boxes	Same side of tank
18	13.3.1	HV terminal arrangement NVD capacitor taps required NVD capacitance if required pF Surge arresters required Brackets for surge arresters required	(iv) / (v) Yes / No 260pF No Yes
19	13.3.2	HVN terminal arrangement	* (i) / (ii)
20	13.3.3	LV Terminal arrangement  Number and size of single core cables to be terminated LV cable link disconnecting chamber required	* Separable connectors – see Clause 13.3.3 for details LV outdoor bushings  *Yes / No
21	13.3.4	LVN terminal arrangement Number and size of single core cable to be terminated LVN current transformer(s) required  Details of LVN current transformer(s)	* (i) / (ii)  No – Mounting bracket only required
22	13.3.5	Auxiliary Transformer required	* Yes / No
23	13.4.1	Max / min tap position indicator required	No
24	13.6.5	Winding temperature indicator or sensor Output required from sensor Winding temperature indicator type Second WTI or sensor required Electronic WTI d.c. supply voltage Minimum (V) Maximum (V)	Indicator / Sensor  * Dial / Electric No
25	13.6.6	Second voltage compounding CT required	No, but space for a second one shall be provided.

**MANUFACTURERS AND PLACES OF MANUFACTURE, TESTING AND INSPECTION**

*(To be completed by Tenderer)*

<b>MANUFACTURERS AND PLACES OF MANUFACTURE, TESTING AND INSPECTION</b> <i>(To be completed by Tenderer)</i> Item	<b>Manufacturer's Drawing Number and/or Type Designation</b>	<b>Manufacturer</b>	<b>Place of Manufacture</b>	<b>Place of Testing and/or Inspection</b>
Transformers Complete				
On-load Tap-change Equipment				
HV Bushings				
LV Bushings				
Neutral Bushings				
Radiators				
Pipework Expansion Devices				
Oil Valves				
Oil Pumps				
Oil Pump Motors				
Fans				
Fan Motors				
Dehydrating Breather				
Gas and Oil Actuated Relay(s)				
Outdoor Marshalling or Composite Cubicle				
Indoor Control Cubicle				
Temperature Indicating Devices				
Auxiliary Transformer				
Material for Anti-vibration Mounting				
Noise Enclosure				
Test Equipment / Company used for FRA tests				
Any deviation from this Schedule shall be notified in writing as soon as possible for the Purchaser's approval				

**TECHNICAL SCHEDULE**

*(To be completed by Tenderer)*

Item	Description	7.5/15 Star Star	7.5/15 Delta Star	12/24 Star Star	12/24 Delta Star	12/24 Delta Star Dual Ratio	20/40 Delta Star	20/40 Star Star
	MAGNETIC CIRCUIT							
1.	Core							
	(a) Maximum flux density (Tesla)							
	Construction of core							
	(b) Taped/banded/bolted limbs							
	(c) Taped/banded/bolted yokes							
	(d) Taping/banding material (as applicable)							
2.	Insulation of:							
	(a) Core bolts							
	(b) Core bolt washers							
	(c) Side plates							
	(d) Core laminations							
	WINDINGS							
3.	Types and arrangements of:							
	(a) HV windings							
	(b) LV windings							
	(c) Tapping windings (as applicable)							
	(d) Winding arrangement ie Core/...../...../...../.....							
4.	Conductor Insulation:							
	(a) HV windings							
	(b) LV windings							
	(c) Tapping windings (as applicable)							
5.	Oil circulation (eg neutral/partially directed/directed):							
	(a) To windings -							
	(i) HV windings							
	(ii) LV windings							
	(iii) Tapping windings (as applicable)							
	(b) Through windings -							
	(i) HV windings							
	(ii) LV windings							
	(iii) Tapping windings (as applicable)							
6.	Short circuit capability:							
	(a) Potential axial thrust for worst fault condition of each winding-							
	(i) HV windings, tonnes							
	(ii) LV windings, tonnes							
	(iii) Tapping windings (as applicable) tonnes							



**APPENDIX 3 (Cont'd)**

Item	Description			7.5/15	7.5/15	12/24	12/24	12/24	20/40	20/40
				Star	Star	Star	Star	Star	Star	Star
								Dual Ratio		
6.	Short circuit capability (Cont'd):									
	(b)	Coil clamping short circuit withstand capacity -								
	(i)	HV windings	tonnes							
	(ii)	LV windings	tonnes							
	(iii)	Tapping windings (as applicable)	tonnes							
7.	Current density in windings (at normal tapping position):									
	(a)	HV windings (ER)	A/mm <sup>2</sup>							
	(b)	LV windings (ER)	A/mm <sup>2</sup>							
	(c)	Tapping windings (as applicable) (ER)	A/mm <sup>2</sup>							
	PERFORMANCE CHARACTERISTICS									
8.	Rated power OFAF at 20°C ambient and hot spot temperature of 98°C		MVA							
9.	Hotspot temperature ONAN at 20°C ambient		°C							
10.	No load loss at normal tap (excluding cooling plant loss)		kW							
11.	Cooling plant loss		kW							
12.	Load losses:									
	(a)	ONAN rating, 75°C, normal tapping	kW							
	(b)	CER at 115°C, extreme negative tapping	kW							
13.	Transformer Sound Power Level dBA Cooler Sound Power Level dBA									
14.	TANK AND COOLER THICKNESS									
	(a)	Tank Sides	mm							
	(b)	Tank Base	mm							
	(c)	Tank Cover	mm							
	(d)	Radiator plates								
15.	Total oil required (including cooling system)		litres							

**APPENDIX 3 (Cont'd)**

Item	Description		7.5/15	7.5/15	12/24	12/24	12/24	20/40	20/40
			Star Star	Delta Star	Star Star	Delta Star	Delta Star Dual Ratio	Delta Star	Star Star
16.	Volume of oil to be removed:								
	(a)	To gain access to core earthing link	litres						
	(b)	To effect in-situ change of hv bushing	litres						
	(c)	To change CT's	litres						
17.	Total volume of conservator(s)		litres						
18.	Volume of oil in conservator between highest and lowest visible levels		litres						
19.	Continuous rating of oil pump motor		shaft kW						
20.	Starting current of oil pump motor		amp						
21.	Total number of fans								
22.	Nominal diameter of fans		mm						
23.	Speed of fans		rev/min						
24.	Continuous rating of each fan motor		shaft kW						
25.	Starting current of each fan motor		amp						
	GENERAL								
26.	Filling medium for transport								
27.	Total weight as installed in service, including cooler plant, all fittings and oil		tonnes						
28.	Weight of cooler, complete with oil, conservator etc.		tonnes						
	TAPCHANGER								
29.	Maintenance requirements - (eg years/operations) describe:								
30.	Vol of oil to be removed for tapchanger maintenance		litres						
31.	Cost of parts required for tapchanger maintenance - Itemised list.		£						
32.	PAINT SYSTEM								
	Provide detail of paint system including details of 'on-site' repair system								

Clause 2.0 calls for the transformer and its ancillaries to be designed such that it can continue in operation in times of flood when water levels reach 1m above plinth level. Any exceptions to this shall be listed below:-

<b>Item on Transformer not suitable for submersion and below the 1m level</b>	<b>Reason for non-compliance</b>	<b>Height of flood to which Item will survive</b>	<b>Likely damage and repair necessary after the flood has subsided</b>

## APPENDIX A

### SUPERSEDED DOCUMENTATION

This document supersedes EE SPEC: 8/9 dated January 2020 which should now be withdrawn.

## APPENDIX B

### RECORD OF COMMENT DURING CONSULTATION

No comments received

## APPENDIX C

### ASSOCIATED DOCUMENTATION

**ENA Technical Specification 35-2 Issue 6 - 2014**  
Eco design regulation 2009/125/EC  
IEC 60296

A hyperlink to that document is provided below for use by WPD staff.

[ENA Technical Specification 35-2, Issue 6, 2014 - Emergency Rated System Transformers 66/20.5kV, 66/11.5kV and 33/11.5kV Delta/Star and Star/Star Connected.](#)

It should be noted that this document is copyright and shall not be passed outside WPD. Copies can be purchased from Energy Networks Association. Manufacturers tendering WPD would be expected to already hold a copy.

## APPENDIX D

### IMPACT ON COMPANY POLICY

Introduction of standard 66kV impedance envelopes and minimum flow rate for Buchholz relays.

## APPENDIX E

### KEY WORDS

Transformer, CER, CMR, Tapchanger.