

# Hereford – Ledbury Ring



DNOA Decision

**Reinforce with Flexibility**

## Scheme description

The Hereford 66 kV ring includes a solar farm and a number of 66/11 kV primary substations fed via two 66 kV circuits from Hereford BSP. During an outage on either of these infeeds, the volts at the solar farm could drop to below statutory limits. The conventional reinforcement solution is to install a STATCOM to improve the voltage regulation, upgrade the isolators at Ledbury and install a new 66 kV feeder bay with a circuit breaker and two new isolators at Brotheridge Green.



Constraint Season  
**Winter**



Flexibility Product  
**Secure**



## Constraint management timeline

**2023 H1 Procurement**  
**2022 H2 Procurement**  
**2022 H1 Procurement**  
**2021 H2 Procurement**  
**2021 H1 Procurement**  
**2020 H2 Procurement**  
**2020 H1 Procurement**

**EPRC: 2024**

## Estimated flex availability price (£) and volumes (MWh) per year :

	2023	2024	2025	2026	2027
<b>BV</b>	£1252 / 45 MWh	£500 / 115 MWh			
<b>CT</b>	–	£377 / 152 MWh			
<b>LTW</b>	–	£146 / 392 MWh			
<b>ST</b>	–	£771 / 75 MWh			
<b>SP</b>	–	£1252 / 33 MWh			

## Estimated flex utilisation price (£) and volumes (MWh) per year:

	2023	2024	2025	2026	2027
<b>BV</b>	£1753 / 45 MWh	£700 / 115 MWh			
<b>CT</b>	–	£527 / 152 MWh			
<b>LTW</b>	–	£205 / 392 MWh			
<b>ST</b>	–	£1079 / 75 MWh			
<b>SP</b>	–	£1753 / 33 MWh			



For more information visit: [nationalgrid.co.uk/network-flexibility-map-application](https://nationalgrid.co.uk/network-flexibility-map-application)