

# Grendon - Corby 132 kV



## Scheme description

Under an SCO on two of the 132 kV circuits between Grendon GSP and Corby BSP the remaining two 132 kV circuits could potentially overload. There are a number of projected constraints in the area (both demand and generation driven). Various solutions are being considered to manage these constraints, including building a new Grid Supply Point.



Constraint Season  
Winter/Summer



Flexibility Product  
Secure

## Justification for decision


Flexibility procurement is necessary to manage this constraint. Cost Benefit Analysis indicates flexibility is the optimum solution until at least 2026 under WPD Best View and 2025 under all scenarios.

## Constraint management timeline

2022 H2 Procurement  
2022 H1 Procurement

## Estimated flex utilisation required per year (MWh):

	2022	2023	2024	2025	2026
<b>BV</b>	136.01	405.35	647.06	1114.34	2139.54
<b>CT</b>	166.80	542.12	988.81	1909.21	
<b>LTW</b>	161.23	569.94	987.36	1965.69	
<b>ST</b>	92.39	231.25	278.38	363.92	486.83
<b>SP</b>	70.89	172.94	196.02	216.27	242.81



For more information visit: [www.westernpower.co.uk/network-flexibility-map-application](http://www.westernpower.co.uk/network-flexibility-map-application)