

# Union Street - Rugby


 DNOA Decision  
**Flexibility**

**Scheme description**

Union Street Primary has two 33/11kV transformers. For an FCO on one of these transformers the other is left supplying the full demand. This substation has been identified as being at its limit for firm capacity.



Constraint Season  
Winter



Flexibility Product  
Secure

**Justification for decision**

Analysis indicates minimal constraint at present. Current flexibility contracts are being maintained to retain confidence in the market.

**Constraint management timeline**

- 2022 H2 **Maintain Active**
- 2022 H1 Maintain Active
- 2021 H2 Procurement
- 2021 H1 Procurement
- 2020 H2 Procurement
- 2020 H1 Procurement

**Estimated flex utilisation required per year (MWh):**

	2022	2023	2024	2025	2026
BV	14.73				
CT	21.19				
LTW	23.38				
ST	5.42				
SP	2.80				

