

# Taunton GSP



## Scheme description

The Bridgwater GSP and Taunton GSP operate in parallel and are interconnected with two 132 kV circuits. The group requires SCO restoration for the loss of any of the SGTs in the group.

National Grid are installing a second SGT at Taunton as part of the Hinkley Point C connection works.



Constraint Season  
Winter



Flexibility Product  
Dynamic



## Justification for decision


Reinforcement works have been completed. Existing flexibility contracts are being maintained to retain confidence in the market.

## Constraint management timeline

- 2022 H2 **Maintain Active**
- 2022 H1 Maintain Active
- 2021 H2 Maintain Active
- 2021 H1 Maintain Active
- 2020 H2 Procurement
- 2020 H1 Procurement

## Estimated flex utilisation required per year (MWh):

	2022	2023	2024	2025	2026
BV	70.39				
CT	150.86				
LTW	137.91				
ST	44.43				
SP	16.95				



For more information visit: [www.westernpower.co.uk/network-flexibility-map-application](http://www.westernpower.co.uk/network-flexibility-map-application)