

Hinksford – Wribbenhall 33 kV

Scheme description

Thermal overloads projected on the Hinksford-Wribbenhall 33 kV network along with voltage constraints. Proposed reinforcement is to carry out circuit works and reconfigure the network.

.....

Justification for decision

Flexibility is not suitable to deal with this restriction as there is a severe voltage constraint.

.....

Reinforcement Information

Completion Year 2025
Current Status Preliminary



DNOA Decision
Reinforce

Shelton

Scheme description

Limited capacity on the Shrewsbury 33 kV meshed network. Proposed reinforcement is to carry out circuit works and reconfigure the network.

.....

Justification for decision

Flexibility is not suitable to deal with this constraint due to its complexity.

.....

Reinforcement Information

Completion Year 2026
Current Status Preliminary



DNOA Decision
Reinforce

