

Olney Primary



DNOA Decision
Signposting

Constraint description

Olney primary has two 33/11 kV transformers. Following an arranged or fault outage on one of the transformers the full site demand is picked up by the other transformer.

Reinforcement description

Uprating both 33/11 kV transformers at Olney primary would free up some capacity. Further capacity could be released through 33 kV circuit works (which could synergise with the overall plan for the Northampton 33 kV network).



Constraint Season
Winter and Summer



Outage Type
N-1



Justification for decision

No flexibility requirement under Best View until 2033.

Constraint management timeline

2024 H2 Signposting

Time to Reinforce: 3 years

Constraint Type: Demand

Estimated flexibility volumes (MWh) per year under Best View:

2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
-	-	-	-	-	-	-	-	-	2 MWh	11 MWh



For more information see the **The Northampton Group NDP report:** <https://www.nationalgrid.co.uk/dso/network-development-plan>