

Bath Road Primary



DNOA Decision

Signposting

Constraint description

Bath Road primary transformer overload for the loss of one transformer.

Reinforcement description

Replace the transformers with larger units.



Constraint Season
Winter and Summer



Outage Type
N-1



Justification for decision

No flexibility requirement under Best View until 2034.

Constraint management timeline

2024 H2 Signposting

Time to Reinforce: 3 years

Constraint Type: Demand

Estimated flexibility volumes (MWh) per year under Best View:

2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
-	-	-	-	-	-	-	-	-	-	29 MWh



For more information see the **Bridgwater BSP and 132 kV NDP report**: <https://www.nationalgrid.co.uk/dso/network-development-plan>