

Park Lane

 DNOA Decision
Signposting

Constraint description

Park Lane primary is a 7.5/15 MVA primary that is getting close to its capacity for a loss of either transformer.

Reinforcement description

Upgrading both transformers to 12/24 MVA units.



Constraint Season
Winter



Outage Type
N-1

Justification for decision

No flexibility requirement under Best View until 2029.

Constraint management timeline

2024 H2 Signposting

Time to Reinforce: 3 years

Constraint Type: Demand

Estimated flexibility volumes (MWh) per year under Best View:

2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
-	-	-	-	-	1 MWh	4 MWh	16 MWh	55 MWh	102 MWh	186 MWh



For more information see the **East Yelland BSP NDP report:** <https://www.nationalgrid.co.uk/dso/network-development-plan>