

# Portishead to Weston in Gordano

 DNOA Decision  
**Signposting**

**Constraint description**

A 33 kV circuit overload is predicted under intact conditions.

**Reinforcement description**

33 kV circuit reinforcement.



Constraint Season  
Winter



Outage Type  
Intact

**Justification for decision**

No flexibility requirement under Best View until 2030.

**Constraint management timeline**

2024 H2 Signposting

**Time to Reinforce:** 3 years

**Constraint Type:** Demand

**Estimated flexibility volumes (MWh) per year under Best View:**

2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
-	-	-	-	-	-	2 MWh	15 MWh	77 MWh	252 MWh	634 MWh



For more information see the **Portishead BSP NDP report:** <https://www.nationalgrid.co.uk/dso/network-development-plan>