

Taunton to Wellington

 DNOA Decision
Signposting

Constraint description

33 kV circuit overload under N-1 outage conditions.

Reinforcement description

33 kV circuit reinforcement.



Constraint Season
Winter and Summer



Outage Type
N-1



Justification for decision

No flexibility requirement under Best View until 2032.

Constraint management timeline

2024 H2 Signposting

Time to Reinforce: 3 years

Constraint Type: Demand

Estimated flexibility volumes (MWh) per year under Best View:

2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
-	-	-	-	-	-	-	-	1 MWh	4 MWh	12 MWh



For more information see the **Taunton BSP NDP report**: <https://www.nationalgrid.co.uk/dso/network-development-plan>