

Tiverton to Stoneshill Farm

 DNOA Decision
Signposting

Constraint description

A fault on the circuit out of Tiverton Bulk Supply Point (BSP) (2L5) causes an overload on the other leg of the ring.

Reinforcement description

Re-conductoring the circuit from Tiverton BSP to Stoneshill Farm and Cullompton.



Constraint Season
Winter and Summer



Outage Type
N-1



Justification for decision

No flexibility requirement under Best View until 2031.

Constraint management timeline

2024 H2 Signposting

Time to Reinforce: 3 years

Constraint Type: Demand

Estimated flexibility volumes (MWh) per year under Best View:

| 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 |
|------|------|------|------|------|------|------|-------|--------|--------|---------|
| - | - | - | - | - | - | - | 4 MWh | 10 MWh | 37 MWh | 115 MWh |



For more information see the **Tiverton BSP NDP report**: <https://www.nationalgrid.co.uk/dso/network-development-plan>