

Hinckley BSP



DNOA Decision

Remove

Constraint description

Hinckley Bulk Supply Point (BSP) consists of two 132/33 kV transformers (fed from Coventry Grid Supply Point (GSP)) and two 132/11 kV transformers (fed from Enderby GSP). The constraint is on the 132/11 kV transformers – either transformer potentially overloads following the loss of the other.

Reinforcement description

No reinforcement required at this time.



Constraint Season
Summer



Flexibility Product
Secure



Outage Type
N-1



Justification for decision

No constraint has been identified.

Constraint management timeline

2024 H1 **None**
2023 H2 Maintain Active
2023 H1 Maintain Active
2022 H2 Maintain Active
2022 H1 Maintain Active
2021 H2 Maintain Active
2021 H1 Maintain Active
2020 H2 Procurement
2020 H1 Procurement

Time to Reinforce: N/A

Constraint Type: Thermal

Estimated flexibility price (£) and volumes (MWh) per year under Best View:

	2024	2025	2026	2027	2028	2029
Availability	-	-	-	-	-	-
Utilisation	-	-	-	-	-	-



For more information visit: nationalgrid.co.uk/network-flexibility-map-application