

# Stokenham



## Constraint description

Stokenham primary is a single 33/11 kV transformer site with firm capacity reliant on 11 kV interconnection. The capacity is expected to be exceeded for an outage of the transformer.

## Reinforcement description

Installing a second primary transformer, a new 11 kV switchboard, and a new additional 33 kV infeed to the site.



Constraint Season  
Winter/Summer



Flexibility Product  
Secure



Outage Type  
N-1

## Justification for decision

No constraint has been identified.

## Constraint management timeline

2024 H1 None  
2023 H2 Maintain Active  
2023 H1 Maintain Active  
2022 H2 Procurement  
2022 H1 Procurement  
2021 H2 Signposting  
2021 H1 Signposting  
2020 H2 Procurement  
2020 H1 Procurement

Time to Reinforce: N/A

Constraint Type: Security of supply

## Estimated flexibility price (£) and volumes (MWh) per year under Best View:

	2024	2025	2026	2027	2028	2029
Availability	-	-	-	-	-	-
Utilisation	-	-	-	-	-	-



For more information visit: [nationalgrid.co.uk/network-flexibility-map-application](https://nationalgrid.co.uk/network-flexibility-map-application)